

# PLANT INSPECTION REPORT

Munich RE 



HSB Engineering Insurance

Policy: H9S086179

Previous Report: 230315-007-0025SB2

Site: 00001

Report Number: 220316-006-0027PL1

PIR1

Occupier THE GALLEON LEISURE CENTRE

Address 99 Titchfield Street, Kilmarnock  
East Ayrshire, KA1 1QY

Sched No.	Plant Code	Item	Remarks
B0018	B04A10	Hot Water Storage Cylinder S.No.:FD11795253 Andrews SWP: 10.35 bar Max Locn.:Dry Sports, Plant Room	No apparent defects. Capacity: 454 litres Maximum working pressure: 10.35 bar
B0027	B04A10	Hot Water Storage Cylinder S.No.:LA33767425 Andrews SWP: 10.3 bar Max Locn.:Dry Sports Plant Room.	No apparent defects. Capacity: 454 litres
B0015	B05A10	Expansion Vessel S.No.:22386/1 Pullen Locn.:Dry Sports, Plant Room	Visual examination with random ultrasonic thickness measurements. Capacity: 60 litres Charge pressure: 4 bar  Corrosion at top plug - to monitor. No other apparent defects.
B0016	B05A10	Pressure Vessel S.No.:22386/2 Pullen Locn.:Dry Sports, Plant Room	Visual examination with random ultrasonic thickness measurements - no apparent defects. Capacity: 60 litres Charge pressure: 4 bar
B0021	B37A10	Heat Exchanger (Plate type) S.No.:11156A UK Exchangers Ltd SWP: 6 bar Max	No apparent defects. Capacity: 4 litres/side. Working at: 2.0 bar.
B0022	B37A10	Heat Exchanger (Plate type) S.No.:11156B UK Exchangers Ltd SWP: 6 bar Max	No apparent defects. Capacity: 3 litres/side. Working at: 2.0 bar.

CHECKED  
29-3-16

MAINTENANCE  
TO CHECK

This report details a visual inspection relating to the potential capability of the equipment, not for compliance with any regulations unless specified above. (Please see covering letter for statement of compliance requirements).

Date of Inspection: 10 Mar 2016

Date of Last Inspection: 12 Mar 2015

Inspecting Engineer: Mr R Chambers

Date of Next Inspection: 10 Mar 2017

Signature: 

Qualification: Engineer Surveyor

HSB Engineering Insurance Services Limited  
Registered in England and Wales: 03010292,  
New London House, 6 London Street, London EC3R 7LP  
Registered as a branch in Ireland: 906105  
Telephone: 0845 345 5510

HSB Engineering Insurance Services Limited  
is accredited by the United Kingdom  
Accreditation Service

