

REPORT OF PERIODIC THOROUGH EXAMINATION OF HOIST OR LIFT

Munich RE 



HSB Engineering Insurance

as required by the Lifting Operation and Lifting Equipment Regulations 1998;
or the Lifting Operations and Lifting Equipment Regulations (Northern Ireland) 1999;
or the Safety, Health and Welfare at Work (General Application) Regulations 2007 S.I. No. 299.

Policy: H9S086179

Plant Code: L25A11

Previous Report: 230315-015-0025SB2

Site: 00001

Schedule: L0004

Report Number: 220316-014-0027PL1

LOL54

Employer (or owner) of premises	THE GALLEON LEISURE CENTRE
Address	99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
1. (a) Type of hoist or lift and identification number and description	Goods Lift - Electric (Goods Only) Location: Bar Area Ellis & McDougall Identification No.: - Unknown 1986
(b) Date of construction or reconstruction (if ascertainable)	
2. (a) Is this the first thorough examination following installation of the equipment at the above site/location?	No
(b) Were examinations in accordance with an examination scheme?	No
3. Maintenance Are the following parts of the hoist or lift properly maintained and in good working order? If not, state what defects have been found or tests required to confirm continued safe use.	
(a) Enclosure of hoistway or liftway.	Yes
(b) Landing gates and cage gate(s).	Yes
(c) Interlocks on the landing gates and cage gate(s).	Yes
(d) Other gate fastenings.	Yes
(e) Cage or platform and fittings, cage guides, buffers, interior of hoistway or liftway.	Yes
(f) Over-running devices.	Yes
(g) Suspension ropes or chains, and their attachments.	Yes
(h) Safety gear, i.e. arrangements for preventing fall of platform or cage.	N/a
(j) Brakes.	Yes
(k) Worm or spur gearing.	Yes
(l) Other electrical equipment.	Yes
(m) Other parts.	Yes
4. What parts (if any) were inaccessible?	All internal mechanical and electrical parts.
5. Repairs, renewals, tests or alterations required to enable the hoist or lift to continue to be operated with safety (if none enter "None") :-	
(a) defects found which give rise to imminent danger and require attention immediately.	None
(b) defects found which could, in time, give rise to danger and require attention or tests required within the specified time period.	None
6. Maximum safe working load subject to repairs, renewals or alterations (if any) specified at 5.	250 kg
7. Other observations	Last service date: 29/1/16


This is to certify that on the date of examination the hoist or lift was thoroughly examined and unless, otherwise indicated above, was safe to operate, and if the first examination following installation, was installed correctly.

Date of Examination: 10 Mar 2016

Date of Last Examination: 12 Mar 2015

Inspecting Engineer: Mr R Chambers

Date of Next Examination: 10 Mar 2017

Signature: 

Qualification: Engineer Surveyor

HSB Engineering Insurance Services Limited
Registered in England and Wales: 03010292,
New London House, 6 London Street, London EC3R 7LP
Registered as a branch in Ireland: 906105
Telephone: 0845 345 5510

HSB Engineering Insurance Services Limited
is accredited by the United Kingdom
Accreditation Service

