

REPORT OF EXAMINATION OF SYSTEM OR PARTS THEREOF

Policy: H9S086179

Plant Code: B05A12

Previous Report: 220414-007-0022CG3

Site: 00001

Schedule: B0013

Report Number: 220316-007-0027PL1

WRITTEN SCHEME NUMBER: WS01

PS1

1. Name and address of owner	THE GALLEON LEISURE CENTRE 99 Titchfield Street, Kilmarnock East Ayrshire, KA1 1QY
2. Subject to written agreement under the relevant Schedule of the regulations	No
3. Location of systems and name of user if different from above	Pool Plant Room
4. (a) System identification (b) Identification of part of system (c) Description of part of system	PS01 Whole Pressure Vessel Boss Serial No.:- 11181
5. Results of examination and condition of parts examined in accordance with Written Scheme of Examination	Thorough and Working Examination with random ultrasonic thickness measurements: recorded 2.70 mm. Internals of Vessel: inaccessible. Remains suitable for further service.
6. Repairs (if any) required in order to prevent imminent danger If none enter "None"	None
7. Defects (other than those specified at 6 above) which require attention If none enter "None"	None
8. (a) Safe operating limit (b) Change in safe operating limits and date by which required If none enter "None"	6 bar None
9. Change in written scheme if required If none enter "None"	None
Postponement (Section 9(7)) Name of Competent Person Name of Users Representative Date of Postponement Date of limit of Postponement If none enter "None"	None
11. Other observations	Seen working at 2.0 bar. Capacity: 1000 litres.

Certification :- I certify that the above system or parts thereof was examined in accordance with the Written Scheme of Examination and that the above is a true report of the result.

Inspecting Engineer: Mr. R. Chambers
Qualification: Engineer Surveyor

Signature: 

	Thorough	Working
Date of Examination:	10 Mar 2016	10 Mar 2016
Date of Last Examination:	11 Apr 2014	12 Mar 2015
Date of Next Examination:	10 May 2018	10 Apr 2017